


**INSTALLATION INSTRUCTIONS:**


- A. PROVIDE WALL WITH ADEQUATE BACKING (1) TO MOUNT CABINET.
- B. DRILL HOUSING (2) TO LOCATE MOUNTING POINTS WHERE BACKING EXISTS. REMOVE HOUSING (2) AND INSTALL WALL ANCHORS (3) (BY OTHERS) AS REQUIRED FOR WALL TYPE CONSTRUCTION.
- C. INSTALL FIRE EXTINGUISHER HOUSING (2) ONTO THE WALL (1).
- D. FASTEN FIRE EXTINGUISHER HOUSING (2) ONTO THE WALL USING SCREWS (BY OTHERS) TO SUIT WALL CONSTRUCTION.

**IMPORTANT!** AFTER INSTALLATION, ALL JOINTS REQUIRE SECURITY SEALANT BY INSTALLER TO ELIMINATE GAPS BETWEEN WALL AND FIXTURE.

LOCATE ITEM TO CONFORM WITH APPLICABLE CODES FOR ACCESSIBILITY.



NOTE:  
WEIGHT WITHOUT FIRE EXTINGUISHER = 15.5 lbs.

 WHITEHALL MANUFACTURING P.O. BOX 3527 Industry, CA 91744 15125 Proctor Ave Industry, CA 91746 (626) 968-6681 FAX (626) 855-4862	<b>TITLE</b> <b>LIGATURE RESISTANT SURFACE MOUNT EXTINGUISHER CABINET WH1754-A</b>		
	<b>MANUFACTURE DATE</b> <b>AUGUST 2018</b> <b>TO PRESENT</b>	<b>DATE ISSUED</b> <b>10/12/2022</b>	<b>DRAWING NUMBER</b> <b>9918-137-001</b>